



October 19, 2021

Town of Rouleau
Box 250
Rouleau, SK, S0G 4H0

Dear Waterworks Owner/Operator:

RE: Rescinding Precautionary Drinking Water Advisory – Town of Rouleau

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Moose Jaw Office, is advising that the **“Precautionary Drinking Water Advisory” (PDWA)** issued for the Town of Rouleau distribution system has been rescinded, as of October 19, 2021.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Town of Rouleau in addressing the advisory.

For further information please do not hesitate to contact the undersigned at (306) 630-8476 or rod.broughton@wsask.ca.

Sincerely,

A handwritten signature in blue ink, appearing to read "Rod Broughton".

WATER SECURITY AGENCY
Rod Broughton
Environmental Project Officer
Environmental Services Section - South
Environmental and Municipal Management Services Division

cc: Roger Miller, Water Security Agency
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Moose Jaw